


# Retro-fit Gas Logs

## Gas Pipe Tests

Retro-fit gas logs/fireplaces will need a gas pipe test whether installed by a person licensed by the State of Colorado or Larimer County.

Please be aware of the following prior to testing:



1. Gas pipe tests may be performed and verified by a person licensed for gas piping in lieu of an inspection by a Larimer County Building Inspector. **This applies to gas log installation only.**

If a person licensed for gas piping does not fill out the attached form letter then an inspection will need to be completed by Larimer County.

2. The test shall be at 10# air pressure for a minimum duration of 10 minutes.
3. After installation is complete with logs in place and operable, call 498-7697 or visit **<https://onlineportal.larimer.org/Public/Main>** to schedule a final inspection by the county Building Department.
4. The attached form letter must be filled out and left with the inspection card at the job site.



## COMMUNITY DEVELOPMENT DIVISION

P.O. Box 1190  
Fort Collins, CO 80522-1190  
Building Department (970) 498-7700  
Fax (970) 498-7667

# LARIMER COUNTY | COMMUNITY DEVELOPMENT

P.O. Box 1190, Fort Collins, Colorado 80522-1190, Planning (970) 498-7683 Building (970) 498-7700, Larimer.org

**PERMIT #** \_\_\_\_\_

I verify that the gas pipe installed at

(address) \_\_\_\_\_

Maintained 10# pressure for a duration of 10 minutes with no detectable drop in pressure.

With my signature I verify that the pressure test exceeds 2015 International Residential Code or the 2015 International Fuel Gas Code requirements, and I release Larimer County from any liability.

State of Colorado Master Plumber or County Mechanical or Gas Pipe License

Number: \_\_\_\_\_

Company Name: \_\_\_\_\_

Signed: \_\_\_\_\_

Date: \_\_\_\_\_